

Declaration of the Fire Resistance Performance According to TS EN 13501-2

This document issued by Efectis Era Avrasya in consequence of ORBİS PASİF YANGIN KORUMA TEKNOLOJİLERİ AHMET MÜNİR KARACABEY application as the supplier of automatic drop down seal.

The fire resistance test of single leaf fire door fitted with related threshold seal carried out on 19.06.2014 in EFFECTIS ERA AVRASYA laboratory and issued test and classification report. The details of the test and the automatic drop down seal defined below.

Details of the related fire resistance test:

Test Standard	: TS EN 1634-1
Test Report Number and Date of Issue	: RFTR 14024 - 14.08.2014
Classification Report Number and Date of Issue	: EEA-14-017 - 14.08.2014

Details of the intumescent seal which was used in test specimen:

Brand Name and Code	: Automatic drop down seal - FIREX 300.10
Technical Specifications Declared by Supplier	: Self - Extinguishing Silicone seal aluminium inner profile installed ; Intuflex intumescent seal laterals installed
Name and Address of the Supplier	: ORBİS PASİF YANGIN KORUMA TEKNOLOJİLERİ AHMET MÜNİR KARACABEY Mimar Sinan Mah. Üsküdar Cad. YEDPA Ticaret Merkezi D Caddesi No:57 Ataşehir/İSTANBUL
Location	: Bottom of the leaf.
Dimensions	: 12 x 30 mm (w x h)

Direction of the test specimen: Opening towards to fire.

Results of the test according to TS EN 13501-2:


E 90; EI₂ 60

This document is only interprets together with related test report.

Regards,

Oprs-48-2014

22.08.2014 - Kocaeli



Onur DAĞ
Operation Manager

